

PUBLIC NOTICE – MANDATORY LANGUAGE CODING

Tier 2 violation / Non-acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: NON-ACUTE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The CITY OF ANSON, PWS ID TX1270001, failed to meet the minimum treatment technique requirements for the month of APRIL, 2026 on 04/25/2026. Specifically, our water system had:

Violation List:

- Low Disinfection Contact Time (CT) for more than four consecutive hours

Additional Information:

The City of Anson has taken the following corrective action to prevent a recurrence of the violations. This issue was resolved by updating our monthly reports to meet the disinfection contact time. All reports/updates have been submitted to TCEQ.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact water system official at:

Phone: 325-260-3796

Posted / Delivered on:

06-01-2026